



01761223

Axelson, John

From: Axelson, John
Sent: Wednesday, April 06, 2011 9:09 AM
To: 'burkhart80526@msn.com'
Cc: 'darylburkhart@hotmail.com'
Subject: Water Quality Results #200300876

Cynthia,

After I sent you the report yesterday I realized I did not mention in the text of the letter that the result for manganese also slightly exceeded the secondary standard. The result was 0.052 mg/L and the CDPHE secondary standard is 0.05 mg/L. All results were still below the CDPHE human health standards for drinking water. The result was included on Table 1 – of the analytical summary, but I apologize for the omission in the text of the letter.

Manganese is naturally occurring in rocks and sediments and is commonly detected in water samples collected from wells completed in the Laramie-Fox Hills aquifer in northern Weld County.

If you have any questions, please give me a call.
Thank you,

John Axelson, P.G.
Environmental Protection Specialist, Northeast Region
Colorado Oil & Gas Conservation Commission
Phone: 303-637-7178
Cell: 303-877-9964
Fax: 303-637-7179