

K9OU Pad

Inspection# 675201209

Sign missing tank capacity.



No source containment
around tanks.



No source containment
around tanks.

