

Inspection Photos – NTO Pressure testing
Location Name: 4" Condensate PCU2 to
BSTB
Facility ID: 451019



Photo 1. Gauge at beginning of test. 69.1 psi.



Photo 2. Gauge after 15 minute test. 66.8 psi.