

PUCKETT 33B-7D
API# 05-045-10266
Inspection # 689702142



11.28.2018 14:11



COLORADO
Oil & Gas Conservation
Commission
Department of Natural Resources

PUCKETT 33B-7D
API# 05-045-10266
Inspection # 689702142



Methanol tank is missing operator name, number, and capacity.

PUCKETT 33B-7D
API# 05-045-10266
Inspection # 689702142



Capacity label on produced water tank is faded and cracking.