

Pressure Test Inspection



Total Records: 15

Location Name: H26NW

Line Name	Test Date	Representative	Start Pressure (psi)	End Pressure (psi)	Start Time	End Time	Duration	Test Result
Benzel 26-7A (H26NW)	2019-08-20	Chris Long	271	271	10:00:00	10:30:00	00:30:00	Pass
Benzel 26-7B (H26NW)	2019-08-20	Chris Long	244	244	10:00:00	10:30:00	00:30:00	Pass
Benzel 26-7B1 (H26NW)	2019-08-20	Chris Long	225	225	10:00:00	10:30:00	00:30:00	Pass
Benzel 26-8A (H26NW)	2019-08-20	Chris Long	221	221	10:00:00	10:30:00	00:30:00	Pass
Benzel 26-8B (H26NW)	2019-08-20	Chris Long	201	200	10:00:00	10:30:00	00:30:00	Pass
Benzel 26-8C (H26NW)	2019-08-20	Chris Long	182	182	10:00:00	10:30:00	00:30:00	Pass
Benzel 26-9B (H26NW)	2019-08-20	Chris Long	195	195	10:00:00	10:30:00	00:30:00	Pass
H26NW DUMPLINE TO 20' TANK 81110	2019-08-20	Chris Long	95	95	10:00:00	10:30:00	00:30:00	Pass
H26NW DUMPLINE TO 20' TANK 81111	2019-08-20	Chris Long	87	87	10:00:00	10:30:00	00:30:00	Pass
H26NW COMBUSTOR VAPOR LINE	2019-08-20	Chris Long	62	62	10:00:00	10:30:00	00:30:00	Pass
H26NW SALES LINE	2019-08-20	Chris Long	101	101	10:00:00	10:30:00	00:30:00	Pass
H26NW SUPPLY GAS TO COMBUSTOR	2019-08-20	Chris Long	40	40	10:00:00	10:30:00	00:30:00	Pass
H26NW SUPPLY GAS TO TANK HEATERS	2019-08-20	Chris Long	37	37	10:00:00	10:30:00	00:30:00	Pass
Lazier 26-1A (H26NW)	2019-08-20	Chris Long	561	560	10:00:00	10:30:00	00:30:00	Pass
Lazier 26-2 (H26NW)	2019-08-20	Chris Long	241	241	10:00:00	10:30:00	00:30:00	Pass