

Location

Overall Good:

Signs/Marker:			
Type	TANK LABELS/PLACARDS		
Comment:	1st and 3rd Tank from the North are missing Capacity Labels, see photos		
Corrective Action:	Comply with Rule 210.d.	Date:	03/16/2020
Type	WELLHEAD		
Comment:	Adequate		
Corrective Action:		Date:	
Type	BATTERY		
Comment:	Adequate		
Corrective Action:		Date:	

Emergency Contact Number:			
Comment:	<input type="text"/>		
Corrective Action:	<input type="text"/>		Date: _____

Good Housekeeping:			
Type	STORAGE OF SUPL		
Comment:	Unused Chemical Tank and Containment. See photos. If still in use, please stand Chemical Tank back up and install wildlife netting on Secondary Containment		
Corrective Action:	Comply with Rule 603.f.	Date:	03/16/2020

Overall Good:

Spills:			
Type	Area	Volume	

In Containment: No
 Comment:
 Multiple Spills and Releases?

Fencing/:			
Type	LOCATION		
Comment:	Barbed Wire		
Corrective Action:		Date:	

Equipment:				corrective date
Type: Bird Protectors	# 4			
Comment:				
Corrective Action:		Date:		
Type: Compressor	# 1			
Comment:				
Corrective Action:		Date:		
Type: Gas Meter Run	# 3			
Comment:				
Corrective Action:		Date:		

Type: Plunger Lift	# 1		
Comment:			
Corrective Action:			Date:
Type: Emission Control Device	# 2		
Comment:			
Corrective Action:			Date:
Type: VRU	# 1		
Comment:			
Corrective Action:			Date:
Type: Bradenhead	# 1		
Comment:	Appears to be plumbed to surface		
Corrective Action:			Date:
Type: Horizontal Heated Separator	# 2		
Comment:			
Corrective Action:			Date:

Tanks and Berms:

Contents	#	Capacity	Type	Tank ID	SE GPS
PRODUCED WATER	1	OTHER	BV CONCRETE		,
Comment:					
Corrective Action:					Date:

Paint

Condition	Adequate
Other (Content)	
Other (Capacity)	60 BBLS
Other (Type)	

Berms

Type	Capacity	Permeability (Wall)	Permeability (Base)	Maintenance
Comment:	Shares berm with the Crude Oil Tanks			
Corrective Action:				Date:

Contents	#	Capacity	Type	Tank ID	SE GPS
PRODUCED WATER	1	300 BBLS	FIBERGLASS AST		,
Comment:					
Corrective Action:					Date:

Paint

Condition	Adequate
Other (Content)	
Other (Capacity)	
Other (Type)	

Berms

Type	Capacity	Permeability (Wall)	Permeability (Base)	Maintenance

Comment: [Shares berm with the Crude Oil Tanks](#)

Corrective Action:	Date:
--------------------	-------

Contents	#	Capacity	Type	Tank ID	SE GPS
CRUDE OIL	5	300 BBLs	STEEL AST		40.741950,-104.000610

Comment:

Corrective Action:	Date:
--------------------	-------

Paint

Condition	Adequate
-----------	----------

Other (Content)

Other (Capacity)

Other (Type)

Berms

Type	Capacity	Permeability (Wall)	Permeability (Base)	Maintenance
Metal	Adequate	Walls Sufficient	Base Sufficient	Adequate

Comment:

Corrective Action:	Date:
--------------------	-------

Venting:

Yes/No

Comment:

Corrective Action:	Date:
--------------------	-------

Flaring:

Type	
Comment:	
Corrective Action:	Date:

Inspected Facilities

Facility ID: 422563 Type: WELL API Number: 123-33311 Status: PR Insp. Status: PR

Producing Well

Comment: PR

Corrective Action:

Date:

Reclamation - Storm Water - Pit						
Storm Water:						
Loc Erosion BMPs	BMP Maintenance	Lease Road Erosion BMPs	Lease BMP Maintenance	Chemical BMPs	Chemical BMP Maintenance	Comment
Gravel	Pass	Gravel	Pass			
Comment: <input style="width: 90%;" type="text"/> Corrective Action: <input style="width: 90%;" type="text"/>						Date: _____
Pits: <input checked="" type="checkbox"/> NO SURFACE INDICATION OF PIT						

COGCC Comments		
Comment	User	Date
<p>COGCC Inspection Report Summary</p> <p>On Thursday 02/13/2020 at approximately 11:52, I, Inspector Erica Petrie, conducted a Field Inspection at Noble Energy INC, Ptasnik LC20-75HZ, Location ID #422561 in Weld County, Colorado.</p> <p>While there, I observed Production Operations. Winter conditions, snow covered ground at the time of this Inspection.</p> <p>During this inspection the following possible compliance issues were observed:</p> <p>Unused Chemical Tank and Containment. See photos. If still in use, please stand Chemical Tank backup and install wildlife netting on Secondary Containment. Comply with Rule 603.f. Corrective Action date 03.16.2020</p> <p>1st and 3rd Tank from the North are missing Capacity. See photos. Comply with Rule 210.d. Corrective Action date 03.16.2020</p> <p>A follow up on this site inspection will be conducted to ensure the compliance issues have been corrected to comply with COGCC rules. This is a summary of the inspection report.</p> <p>Continuing Educational Inspections</p>	petrie	02/14/2020

Attached Documents

You can go to COGCC Images (<https://cogcc.state.co.us/weblink/>) and search by document number:

Document Num	Description	URL
402314372	INSPECTION SUBMITTED	http://ogccweblink.state.co.us/DownloadDocumentPDF.aspx?DocumentId=5069183
696301314	Photos	http://ogccweblink.state.co.us/DownloadDocumentPDF.aspx?DocumentId=5069181