

State of Colorado
Oil and Gas Conservation Commission

1120 Lincoln Street, Suite 801, Denver, Colorado 80203
Phone: (303) 894-2100 Fax: (303) 894-2109



Document Number:

402083150

Date Received:

06/20/2019

FIR RESOLUTION FORM

Overall Status: CAC

CA Summary:

3 of 3 CAs from the FIR responded to on this Form

3 CA Completed
0 Factual Review Request

OPERATOR INFORMATION

OGCC Operator Number: 46290

Name of Operator: KP KAUFFMAN COMPANY INC

Address: 1675 BROADWAY, STE 2800

City: DENVER State: CO Zip: 80202

Contact Name and Telephone:

Name: _____

Phone: () _____ Fax: () _____

Email: _____

Additional Operator Contact:

Contact Name

Susana Lara-Mesa

Phone

303-825-4822

Email

slaramesa@kpk.com

COGCC INSPECTION SUMMARY:

FIR Document Number: 685101184

Inspection Date: 06/19/2019

FIR Submit Date: 06/19/2019

FIR Status: _____

Inspected Operator Information:

Company Name: KP KAUFFMAN COMPANY INC

Company Number: 46290

Address: 1675 BROADWAY, STE 2800

City: DENVER State: CO Zip: 80202

LOCATION - Location ID: 311327

Location Name: JOHN A. KUNZMAN-62N66W Number: 5NWSW County: WELD

Qtrqr: NWS Sec: 5 Twp: 2N Range: 66W Meridian: 6
W

Latitude: 40.165460 Longitude: -104.808270

FACILITY - API Number: 05-123- -00 Facility ID: 241928

Facility Name: JOHN A. KUNZMAN Number: 4

Qtrqr: NWS Sec: 5 Twp: 2N Range: 66W Meridian: 6
W

Latitude: 40.165460 Longitude: -104.808270

CORRECTIVE ACTIONS:

1 ☒ CA# 126218

Corrective Action: Securely fasten all valves, pipes, and fittings to ensure good mechanical condition, inspect at regular intervals and maintain in good mechanical condition per Rule 605.d.

Date: 12/16/2018

Response: CA COMPLETED

Date of Completion: 06/20/2019

Operator Comment: Packing leaking has been repaired. Please see attached pictures.

COGCC Decision: Approved

COGCC
Representative:

2 ☒ CA# 126219

Corrective Action: Since the flaring or venting occurred after flowback without approval, contact the COGCC Area Engineer for next steps per Rule 912.b. Refer to the venting and flaring NTO for further details.

Date: 06/19/2018

Response: CA COMPLETED

Date of Completion: 06/20/2019

Operator
Comment: WH bolts have been tightened. Please see attached pictures.

COGCC Decision: Approved

COGCC
Representative:

3 ☒ CA# 126220

Corrective Action: Securely fasten all valves, pipes, and fittings to ensure good mechanical condition, inspect at regular intervals and maintain in good mechanical condition per Rule 605.d.

Date: 12/16/2018

Response: CA COMPLETED

Date of Completion: 06/20/2019

Operator
Comment: WH has been repaired. Please see attached pictures.

COGCC Decision: Approved

COGCC
Representative:

OPERATOR COMMENT AND SUBMITTAL

Comment:

I hereby certify that the statements made in this form are, to the best of my knowledge, true, correct, and complete.

Print Name: Alan Harrison

Signed: _____

Title: VP of Develop.and Prod.

Date: 6/20/2019 7:35:38 PM

ATTACHMENT LIST

View Attachments in Imaged Documents on COGCC website (<http://ogccweblink.state.co.us/>) - Search by Document Number.

<u>Document Number</u>	<u>Description</u>
402083150	FIR RESOLUTION SUBMITTED
402083151	CA PIC1
402083152	CA PIC2
402083153	CA PIC3
402083154	CA PIC4

Total Attach: 5 Files